

**CROSS CONNECTION CONTROL SURVEY FORM
APPENDIX C**



APPENDIX C: Restaurant

List cross connections that are in addition to the General Form

Date: _____

Facility ID: _____

Facility address, including unit number: _____

Hazards (indicate all that are present)

Post Mix Carbonator

Number: _____ Location(s): _____

Degree of hazard: MODERATE

Protection size, type, and serial number: _____

DCAPC

Other

Required Upgrade: _____

Dishwasher, Commercial

Number: _____ Location(s): _____

Degree of hazard: MODERATE

Protection size, type, and serial number: _____

AVB

Other

Required Upgrade: _____

**CROSS CONNECTION CONTROL SURVEY FORM
APPENDIX C**



Glass Washer

Number: _____ Location(s): _____

Degree of hazard: MODERATE

Protection size, type, and serial number: _____

AVB

Other

Required Upgrade: _____

Steam Tables

Number: _____ Location(s): _____

Degree of hazard: MINOR / MODERATE

Protection size, type, and serial number: _____

Air Gap

Other

Required Upgrade: _____

Cooking Kettles

Number: _____ Location(s): _____

Degree of hazard: MINOR

Protection size, type, and serial number: _____

Air Gap

Other

Required Upgrade: _____

**CROSS CONNECTION CONTROL SURVEY FORM
APPENDIX C**



Dish Rinse Unit with Flex Hose

Number: _____ Location(s): _____

Degree of hazard: MODERATE

Protection size, type, and serial number: _____

Air Gap

Other

Required Upgrade: _____

Potato Peeler

Number: _____ Location(s): _____

Degree of hazard: MINOR / MODERATE

Protection size, type, and serial number: _____

Air Gap

Other

Required Upgrade: _____

Fume Hood with Water Connection

Number: _____ Location(s): _____

Degree of hazard: SEVERE

Protection size, type, and serial number: _____

Required Upgrade: _____

**CROSS CONNECTION CONTROL SURVEY FORM
APPENDIX C**



Ice Machine

Number: _____ Location(s): _____

Degree of hazard: MODERATE

Protection size, type, and serial number: _____

DCVA

Other

Required Upgrade: _____

Dipper Well for Ice Cream

Number: _____ Location(s): _____

Degree of hazard: MODERATE

Protection size, type, and serial number: _____

Air Gap

Other

Required Upgrade: _____

Other (specify)

Number: _____ Location(s): _____

Degree of hazard:

Minor

Moderate

Severe

Protection size, type, and serial number: _____

Required Upgrade: _____